

**OFFICE OF ASSISTANT ENGINEER,  
P.H. SUB DIVISION,HAJIPUR.**

Lt. No. 141 /Hajipur

Date:- 26/02/2026

**TO WHOM IT MAY CONCERN**

This is to certify that GREEN GARDEN PUBLIC SCHOOL, Hathsarganj, Hajipur, Vaishali, Bihar on the basis of inspection and Water Test Report (Attached) vide Lt. No. 30 Dt 14.02.2026 of Chemist PHED Divisional Lab Hajipur, has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt. This above is valid for a period of one Year.

A.T.M.  
26.2.26  
J.E.

  
26/2/26  
Assistant Engineer  
P. H. Sub-Division, Hajipur

Government of Bihar  
Public Health Engineering Department  
Monthly Water Quality Monitoring Report

प्राप्त - 30 फरवरी 14-02-26

District Name: - Valshah		Division Name: - Hajipur				Sample Collect by: - Self												Month: Feb-2026			Format: I																
Sl. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Vill age cod e	Latitude		Longitude		pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	Total Coli	Report handed over to beneficial or not	Demarcated on of contamina ted sources	Data online or not	Remarks								
							0 <sup>n</sup> Min.	0 <sup>n</sup> Sec	0 <sup>n</sup> Min.	0 <sup>n</sup> Sec																											
1	Hajipur	Nagar Parishad	Hathsganj	Hathsganj	Green Garden Public School					7.3	1.1	218	142	80	19	7	12	92					0.12														
Permissible Limit* in absence of alternate source											6.5-8.5	1.0	500	200	75	30	250	200	0.3	45	200	0.0	0.01														
Unit											NR	NTU	m/s	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	

\* (a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml, (c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

*Devi*  
14-02-26  
Chemist  
PH Division Hajipur